

RainCrow

Environmental

***Asbestos
Six-Month
Report***

***Sheffield City Schools
300 W. 6th Street
Sheffield, AL 35660-2802***

October 13th, 2016

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: Administrative Offices (000)

BUILDING: Central Office NO. 01

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
0	7	1	4	9" Vinyl Floor Tile (Stairways)gray -298 sf	NO
0	8	1	4	Gray Vinyl Stair Treads (Stairways)	NO
0	9	5	0	9" Vinyl Floor Tile (Basement Foyer) black – 891 sf	NO
1	0	5	0	9" Vinyl Floor Tile (Basement Strg Rms) off-wht –625sf Mastic exposed @ one rm	NO
1	1	5	0	Black Cove Base (Basement Strg Rooms) – 182 Lf	NO
1	2	5	0	18" x 36" Ceiling Tile (Storage Rooms & Offices) – 1782 sf	NO glue dots tested positive
1	3	5	0	Black Threshold Strips (Basement Storage Rooms)	NO
1	4	6	0	Pipe Insulation (Boiler) Removed in 7/90	NO
1	5	5	0	9" Vinyl Floor Tile (Basement Storage) olive green – 540 sf	NO
2	0	4	5	12" Vinyl Floor Tile (Café & Kitch) brown & white - 2724 sf	NO
2	3	5	0	Transite Vent Pipe (Annex Strg Room) Not transite but a woven material.	NO
2	4	2	0	Pipe Insulation & Elbows (Basement Foyer @ Ceiling) Most removed in 7/90	NO
1	6	6	0	Transite Panels (Boiler Room Ceiling)	NO
2	8	0	1	6- 3' x10' Black Boards (Top Floor) – 180 sf not listed originally	NO



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
 Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: Administrative Offices (000)

BUILDING: Central Office NO. 01

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
2	9	0	1	2-2' x3' Linoleum Counter Top (Top Floor Sink) – 12 sf	NO not listed originally
3	0	0	1	2x2 Perforated Ceiling Tile (Basement Girls RR) not listed originally	NO
3	1	0	1	2- 6" Light Fixture Heat Shield (Basement Stairs Landing & Hall @ RR)	NO not listed originally
3	2	0	1	4- 6" Transite Pipes @ Gas Ceiling Heaters (Annex) not listed originally	NO
3	3	0	1	4-“Reznor” Gas Ceiling Heaters (Annex) not listed originally	NO 1 Removed @ Kitchen
3	4	0	1	Window Caulking (Thru-out Annex) not listed originally	NO
3	5	0	1	7- 4x7 Laminated Wall Panels (Annex)	NO
				*sink w/black spray-on (Annex kitch)	
				* need caution sign @ basement where pipe insulation is in closet.	
				*3 sinks w/black spray on Annex --- these are recent storage items	All Removed



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: Threadgill (002)

BUILDING: Main Building NO. 01

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
1	1	1	3	Light Fixture Heat Shields (Breeze-way)	NO
1	3	1	0	Sinks W/ Black Spray - 40 sf	NO
1	4	1	0	9" Vinyl Floor Tile (Classrooms)lt grn - 9000 sf covered w/ glue-down carpet	NO
1	5	1	0	9" Vinyl Floor Tile (Hall?) tan/ wht- 3200 sf covered w/ glue-down carpet	NO
1	7	1	0	2x2 –Perforated Ceiling Tile (Classrooms @ Old Central Area)	NO replaced CT @ CR # 125
1	7	B		2x4 – Perforated Ceiling Tile (4-CR Addition Classrooms 126-129) -3500 sf	NO
1	8	6	0	Boiler Insulation (Boiler Room) – 40 sf	NO
1	9	0	1	4- Sinks W/ White spray-on (4 CR Addition CR's 126-129)	NO
2	0	0	1	1- sink W/ grey spray-on (café office)	YES not listed originally
				Removed 2 20x40 area @ café serving area (12" VFT Tan Marbled)	



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: Threadgill (002)

BUILDING: 8 Classroom Addition (1992) NO.: 02

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
1	9	0	1	8 - Sinks W/ Gray Spray-on - 12 sf	NO not listed originally
2	0	0	1	12" Vinyl Floor Tile (Classrooms & Hall) grayish White marbled- 7616 sf	NO not listed originally
2	1	0	1	2- Firedoors (Hall & Entry)	NO not listed originally



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN
CONDITION: RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022
Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 **LEA:** Sheffield City Schools

SCHOOL: Threadgill (002)

BUILDING: Kinder Wing Addition (1992) ? **NO.:** 03

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
2	2	0	1	3 - Sinks W/ Gray Spray-on - 12 sf	NO not listed originally
2	3	0	1	12" Vinyl Floor Tile (3 - Classrooms & Hall) gray marbled - 3192 sf	NO not listed originally
2	4	0	1	2- Firedoors (Hall & Entry)	NO not listed originally



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: Sheffield High School (005)

BUILDING: Main Building NO. 01

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
0	8	7	5	Air Cell Pipe Insulation (Crawl Space)	NO
1	2	1	0	12" Vinyl Floor Tile (Basement Study Hall) tan/ green - 1474 sf Replaced	NO
1	3	6	0	Boiler Insulation (Basement Boiler Room) – 100 sf Removed	NO
1	6	3	0	Tan/ White Floor Tile (Hall) Covered w/new 12" VFT	NO
1	7	1	0	Tan/ White Floor Tile (CR 110) – 40 sf Most Replaced w/new 12" VFT except closets	NO
1	8	1	0	Tan/ White Floor Tile (Classroom 115)– 840 sf Replaced w/new 12" VFT except closets	NO
2	0	1	0	Green/ White Floor Tile (CR 120) –1000 sf Most Replaced or covered w/new 12" VFT???	NO this could be original
3	2			2x4 Ceiling Tile (Thru-out) Most replaced with w/new 2x2 ceiling tile	YES all replaced
3	3	0	1	12" VFT (Back Stage Dress Rms) wht w/blue 580 sf not listed originally	NO
3	4	0	1	12" VFT (Audit Sound Booth) wht /gray marbled- 80 sf not listed originally	NO
3	5	0	1	5- Sinks W/ Black Spray-on (Home-Ec) not listed originally	NO all removed
3	5	0	2	4- Sinks W/ Black Spray-on (Classrooms @ 1976 Addition) not listed originally	NO
3	5	0	3	1- Sink W/ Black Spray-on (ROTC Basement Storage Rm) not listed originally	NO



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK


FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: Sheffield High School (005)

BUILDING: Main Building NO. 01

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
3	6	0	1	1- Sink W/ Gray Spray-on (Library Workroom) not listed originally	NO removed
3	7	0	1	Vinyl Room Dividers (CR's @ 1976 Addition) – 384 sf not listed originally	NO
3	8	0	1	2 – Fire-doors (Hall @ 1976 Addition) not listed originally	NO
3	9	0	1	Painted Sheet Vinyl Floor (ROTC Basement Storage Rm) – 200 sf not listed originally	NO
4	0	0	1	12" Vinyl Floor Tile (ROTC CR's) tan /gray marbled– 1200 sf not listed originally	NO
4	1	0	1	12" Vinyl Floor Tile (Home-Ec CR under sub-floor) tan not listed originally	NO all removed



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
 Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: Sheffield High School (005)

BUILDING: Lunchroom/ Gym Building NO. 02

Homogeneous Digit			Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
1	0	1			9" Vinyl Floor Tile (Hallway)black – 500 sf Replaced w/new 12" VFT	NO
1	0	2			9" Vinyl Floor Tile (Hallway)red – 500 sf Replaced w/new 12" VFT	NO
1	0	3			9" Vinyl Floor Tile (Storage Room) brown streaked – 168 sf	NO removed except for storage room adj. old band room
1	0	4			Red Brick Roll Floor Tile (Office) – 104 sf Could not find.	NO
1	0	8			9" Vinyl Floor Tile (Hall, Café & Sewing Room) brown– 2036 sf Part of Old Café covered w/ carpet.	NO all removed except for 200 sf @ IT storage
1	0	9			5" Black Cove Base (Sewing Room) 102 sf	NO removed
1	1	1			2- Sinks W/ White Spray-on (Special Ed CR @ Gym Entry) not listed originally	NO removed
1	1	2			2x4 Transite Ceiling Tiles (Boys' Locker-room) – 168 sf not listed originally	NO
1	1	3			1- Firedoor (Storage) not listed originally	NO
1	1	4			2- Firedoors (Locker Room) not listed originally	NO
1	1	5			4- Firedoors (Front Entry & Restrooms) not listed originally	NO removed
1	1	6			4- Firedoors (Gym Side Entry) not listed originally	NO
1	1	7			HVAC Expansion Joint (Ceiling HVAC Unit @ Old Café)	NO removed



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: Sheffield High School (006)

BUILDING: Sheffield Head Start Center NO.: 01

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
0	3			Insulation	Yes
0	5			9" Vinyl Floor Tile -red	Yes
0	7			9" Vinyl Floor Tile – blue/ white	Yes
0	9			9" Vinyl Floor Tile - green	Yes
1	3			9" Vinyl Floor Tile - dark brown / red	Yes
1	4			Wall Plaster	Yes
*This building has been sold.					



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN
 CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: L. E. Wilson (009)

BUILDING: Main Building NO. 01

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
0	1	3	0	9" Vinyl Floor Tile (Hallway) white - 3328 sf Replaced w/new 12" VFT	NO
0	2	2	0	9" Vinyl Floor Tile (Office) green - 600 sf (Covered W/ new wood laminated floor)	YES
0	3	2	0	9" Vinyl Floor Tile (Office) brwn w/ white streaks - 144 sf	NO
0	4	3	0	9" Vinyl Floor Tile (Hallway) Drk Brwn Streaked - 3328 sf Replaced w/new 12" VFT	NO
0	6	1	0	9" Vinyl Floor Tile (Classrooms) beige streak - 11,774 sf Replaced or covered w/new 12" VFT @ CR's 103 & 112-115	NO some loose & coming up @ 109 & 106
0	8	6	6	Vinyl Stair Treads (Lobby) green - 240 sf	NO
0	9	1	5	9" Vinyl Floor Tile (Cafe) tan/whte - 2150 sf Replaced or covered w/new 12" VFT	NO
1	0	1	5	9" Vinyl Floor Tile (Cafe) Dark green streak - 1300 sf Replaced or covered w/new 12" VFT	NO
1	1	1	5	9" Vinyl Floor Tile (Cafe) lt green streak - 650 sf Replaced or covered w/new 12" VFT	NO
1	7	1	0	9" Vinyl Floor Tile Trim (Classroom) Drk Brwn - 15 sf	NO
1	9	5	1	9" Vinyl Floor Tile (Library) gray streaked - 1728 sf Replaced w/new carpet except @ media rm & Office	NO
2	0	5	1	9" Vinyl Floor Tile (Library) red streaked - 1728 sf Replaced w/new carpet except @ media rm & Office	NO
2	2	1	0	9" Vinyl Floor Tile (Classroom) Brwn Streaked - 11,774 sf Replaced w/new 12" VFT @ CR 202. CR 201 & 208 Covered W/ New Carpet.	NO



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: L. E. Wilson (009)

BUILDING: Main Building NO. 01

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
2	6	1	4	9" Vinyl Floor Tile (Stairway) Drk Brwn Streaked - 108 sf	NO
2	7	1	4	Vinyl Stair Treads (Stairway) black - 10 sf Removed	NO
3	3			Wall Insulation (Auditorium) – 12 sf Cannot find	NO
3	5			9" Vinyl Floor Tile-green Cannot find	NO
3	6			2x4 –White-worm Ceiling Tile (Thru-out) replaced w/new 2x2 ceiling tile	NO
3	7			2x4 –White Pin-point Ceiling Tile (CR’s 112 – 115 & Cafe) Café not replaced yet	NO replaced w/new 2x2 ceiling tile
4	0			2- 6" Light Fixture Heat Shields (Kithcen Locker Room & Restroom)	NO not listed originally
4	1			HVAC Vibration Dampner (2 nd Floor Teacher Work Rm) grn not listed originally	NO replaced
4	2	0	1	4- Sinks W/ Black Spray-on (CR’s 112 - 115) not listed originally	NO
4	2	0	2	2- Sinks W/ Black Spray-on (CR’s 108 & 212) not listed originally	NO



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
 Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: L. E. Wilson (009)

BUILDING: Gym Building NO. 02

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
0	1	0	1	9" Vinyl Floor Tile (Old Band&Hall) med brown - 2100 sf	NO not listed originally
0	2	0	1	9" Vinyl Floor Tile (Old Band Off.) gray- 128 sf	NO not listed originally
0	3	0	1	9" Vinyl Floor Tile (Music Room & Storage) green - 960 sf	NO not listed originally
0	4	0	1	2x4 -wht-worm Ceiling Tile (LR's, Music & Old Band Rm) -8616 sf	NO not listed originally
0	5	0	1	12"x24" Perforated Ceiling Tile (Court Area) – 5000 sf	NO not listed originally
0	6	0	1	5-"Janitrol" Gas Ceiling Heaters (Gym & Locker Rooms) one replaced	NO not listed originally
0	7	0	1	1-"Reznor" Gas Ceiling Heater (Gym)	NO not listed originally
0	8	0	1	1- Sinks W/ Black Spray-on (Music Room)	NO not listed originally
0	9	0	1	23- 8" Light Fixture Heat Shields (Breeze-way)	NO not listed originally



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
 Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: Maintenance (MS)

BUILDING: Maintenance Shop NO.: 01

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
0	1	2	0	Black Threshold Strips (Office Doorway)	NO
0	2	2	0	Beige Roll Floor Tile Break-room/Off) Covered w/ new 12" VFT.	NO
0	2	7	0	Beige Roll Floor Tile (Restroom) Covered w/ new 12" VFT.	NO
0	3			"Modine" Gas Ceiling Heaters (Shop) not listed originally	NO
0	4			"Hastings" Gas Ceiling Heaters (Shop) not listed originally	NO
0	5			1- Sink W/ Black Spray-on Material (Kitchen) not listed originally	NO



Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN
 CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
Phone: (334) 315-2892

PERIODIC SIX MONTH CHECK

FOR ALL SUSPECT OR KNOWN ACBM

DATE: 10/13/2016 LEA: Sheffield City Schools

SCHOOL: Recreation Center (RC)

BUILDING: Recreation NO.: 01

Homogeneous Digit		Functional Space Digit		Description Of ACBM	Change In * Condition (Y/N)
1	2			Vibration Dampener (11 Air Handling Units Thru-out) 30 sf	NO
1	3	0	1	13 – 3x3 Transite Window Panels (Thru-out Hall) – 117 sf not listed originally	NO
1	4	0	1	Transite Ceiling Panels (Front Porch) not listed originally	NO
1	5	0	1	1- sink W/ black spray-on (Concession Stand)	YES not listed originally



 Signature Of Designated Person

*CONTACT MANAGEMENT PLANNER FOR ACTION IF CHANGE IN
 CONDITION: *RainCrow Environmental 752 Myrick Rd. Deatsville, Al. 36022*
Phone: (334) 315-2892